

June 3, 2005

Mr. George Vanderheyden, Vice President
Calvert Cliffs Nuclear Power Plant, Inc.
Calvert Cliffs Nuclear Power Plant
1650 Calvert Cliffs Parkway
Lusby, MD 20657-4702

SUBJECT: CALVERT CLIFFS NUCLEAR POWER PLANT, UNITS 1 AND 2 - REQUEST
FOR ADDITIONAL INFORMATION (RAI) RELATED TO GENERIC LETTER
2004-02, "POTENTIAL IMPACT OF DEBRIS BLOCKAGE ON EMERGENCY
SUMP RECIRCULATION AT PRESSURIZED-WATER REACTORS"
(TAC NOS. MC4672 AND MC4673)

Dear Mr. Vanderheyden:

By letter dated March 3, 2005, Constellation Energy (the licensee) provided the 90-day response to U. S. Nuclear Regulatory Commission (NRC) Generic Letter (GL) 2004-02 for Calvert Cliffs Nuclear Power Plant, Units 1 and 2. The GL requested the licensee perform an evaluation of the emergency core cooling system and containment spray system recirculation functions in light of the information provided in the GL and, if appropriate, take additional actions to ensure system function. Additionally, addressees were requested to submit to the NRC the information specified in the GL.

The NRC staff has completed its preliminary review of your response and has determined it needs additional information requested in the enclosure to complete our review.

This RAI requests additional information about your overall plans and schedules and not any information on detailed plans or extensive analyses. In light of this, please provide the additional information requested in the enclosure within 45 days of receipt of this letter.

In addition, on page 3 of your GL 2004-02 response, you requested an extension of the completion date for the Unit 1 corrective action to May 31, 2008. Paragraph 2(b) of the Required Information section of GL 2004-02 states that if all corrective actions will not be completed by December 31, 2007, licensees are to describe how the regulatory requirements discussed in the Applicable Regulatory Requirements section of the GL will be met until the corrective actions are completed. Given that information is not required to be provided until September 1, 2005, the staff will not be able to act on your request for an extension until that information is provided.

Mr. George Vanderheyden

- 2 -

If you have any questions, please call me at (301) 415-1030.

Sincerely,

/RA/

Richard V. Guzman, Project Manager, Section 1
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-317 and 50-318

Enclosure: Request for Additional Information

cc w/encl: See next page

Mr. George Vanderheyden

- 2 -

June 3, 2005

If you have any questions, please call me at (301) 415-1030.

Sincerely,
/RA/

Richard V. Guzman, Project Manager, Section 1
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-317 and 50-318

Enclosure: Request for Additional Information

cc w/encl: See next page

DISTRIBUTION:

PUBLIC

RidsAcrsAcnwMailCenter

RidsNrrLADBaxley

RidsNrrDlpmDpr

RidsNrrLASLittle

PDI-1 R/F

RidsNrrDlpmLpdi1 (RLaufer)

RidsRgnlMailCenter

RidsNrrDssaDpr

RidsOgcRp

RidsNrrPMRGuzman

DCullison/DSolorio

MWebb

Accession No.: ML051530304

*RAI input from SPLB without any major change

OFFICE	PDIV-1/PM PDIII-2/PM	PDIV-1/LA	DSSA/SPLB/SP	PDI-1/PM	PDIV-1/SC PDIII-2/SC
NAME	MWebb/JHopkins	DBaxley	DCullison/DSolorio*	RGuzman	DTerao/ GSuh
DATE	6/2/2005	6/2/05	5/23/05	6/3/05	6/3/05

OFFICIAL RECORD COPY

Calvert Cliffs Nuclear Power Plant, Unit Nos. 1 and 2

cc:

President
Calvert County Board of
Commissioners
175 Main Street
Prince Frederick, MD 20678

Mr. Loren F. Donatell
NRC Technical Training Center
5700 Brainerd Road
Chattanooga, TN 37411-4017

Carey Fleming, Esquire
Sr. Counsel - Nuclear Generation
Constellation Generation Group, LLC
750 East Pratt Street, 17th floor
Baltimore, MD 21202

Lou Larragoite
Calvert Cliffs Nuclear Power Plant
1650 Calvert Cliffs Parkway
Lusby, MD 20657-4702

Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 287
St. Leonard, MD 20685

Mr. R. I. McLean, Administrator
Radioecology Environ Impact Prog
Department of Natural Resources
Nuclear Evaluations
580 Taylor Avenue
Tawes State Office Building
Annapolis, MD 21401

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Kristen A. Burger, Esquire
Maryland People's Counsel
6 St. Paul Centre
Suite 2102
Baltimore, MD 21202-1631

Patricia T. Birnie, Esquire
Co-Director
Maryland Safe Energy Coalition
P.O. Box 33111
Baltimore, MD 21218

REQUEST FOR ADDITIONAL INFORMATION
REGARDING GENERIC LETTER 2004-02,
“POTENTIAL IMPACT OF DEBRIS BLOCKAGE ON
EMERGENCY SUMP RECIRCULATION AT PRESSURIZED-WATER REACTORS”
CONSTELLATION ENERGY
CALVERT CLIFFS NUCLEAR POWER PLANT, UNITS 1 AND 2
DOCKET NOS. 50-317 AND 50-318

By letter dated March 3, 2005, Constellation Energy (the licensee) provided the 90-day response to U. S. Nuclear Regulatory Commission (NRC) Generic Letter (GL) 2004-02 for Calvert Cliffs Nuclear Power Plant, Units 1 and 2. The GL requested that addressees perform an evaluation of the emergency core cooling system and containment spray system recirculation functions in light of the information provided in the GL and, if appropriate, take additional actions to ensure system function. Additionally, addressees were requested to submit to the NRC the information specified in the GL. The staff has completed its preliminary review of your response and has determined it needs the following additional information to complete our review:

1. On page 2 of your GL 2004-02 response, you stated the susceptibility of the Unit 1 emergency core cooling system and containment spray system recirculation functions to the adverse effects identified in GL 2004-02 was analyzed using the guidance in NEI 04-07. You did not provide a description of the methodology to be used for the Unit 2 analyses. As requested in GL 2004-02, please provide a description of methodology to be used in the Unit 2 analyses and the planned completion date.
2. In addition, your response did not provide a discussion of your plans or schedule for addressing chemical and downstream effects. Although the GL did not specifically request that the evaluation of these effects be discussed in the 90-day response, please discuss your plans and schedule for evaluating chemical and downstream effects and verify whether your September 1, 2005, response will include an evaluation of these effects.

ENCLOSURE